

Republic of the Philippines  
Department of Science and Technology  
PHILIPPINE TEXTILE RESEARCH INSTITUTE  
General Santos Avenue, Bicutan, Taguig City  
Telefax No. 8371325/8372071 to 80 loc 2366  
URL: <http://www/ptri.dost.gov.ph>  
E-mail: [ptri@dost.gov.ph](mailto:ptri@dost.gov.ph)

SUPPLEMENTAL/BID BULLETIN

ADDENDUM No. 1

This addendum No. 1 is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bidding Documents for the procurement of ONE (1) LOT CONSTRUCTION OF SILKWORM REARING HOUSE TECHNOLOGY CENTER, BRGY. IMELDA, VILLANUEVA, MISAMIS ORIENTAL, PHASE II.

**A. Technical Components:**

1. All wooden doors are suggested to use lever-type door knobs instead of the cylinder type.
2. Air vent should cover nearly full on the 2 longer sides of the building.
3. Use of LED lamps or tubes.
4. Doors are panel type not flush doors except for the CR which is PVC.

**B. Additional Requirement:**

Winning Contractor to submit - As Built Plan (Blue Print) upon completion of the Project.

For guidance and information of all concerned.

  
**CORAZON I. TAPULGO**  
BAC Chairperson

Received by the bidder: \_\_\_\_\_

Date: \_\_\_\_\_